

Project Name: Location: Engineer: Submitted to: Submitted by: Reference:

Performance

Indoor Unit Model No:	FBQ18PVJU
Outdoor Unit Model No:	RZR18PVJU
Rated Cooling Capacity (Btu/hr):	18000
Sensible Capacity (Btu/hr):	14800
Max/Min Cooling Capacity (Btu/hr / kW):	tabook/databook
Cooling Input Power (kW):	2.12
SEER:	17.5
Rated Heating Capacity (Btu/hr):	N/A
Max/Min Heating Capacity (Btu/hr / kW):	tabook/databook
Heating Input Power (kW):	N/A
Heating COP (Btu/hr / Btu/hr):	N/A
HSPF:	N/A

Date: Construction:	
Unit #:	
Drawing #:	

Approval:

Indoor Unit Type:	DC Duct Mounted
Condensing Unit Type:	SkyAir Cool Only
Rated Cooling Conditions	Indoor: 80°F DB/67°F WB Outdoor: 95°F DB/75°F WB
Rated Heating Conditions	Indoor: N/A Outdoor: N/A
Rated Piping Length(ft)	25
Rated Height Separation(ft)	0

Indoor Unit Details

Power Supply (V/Hz/Ph:)	208-230/60/1ph
Power Supply Connections:	L1, L2, Ground
Min Circuit Amps MCA (A):	1.6
Max Overcurrent Amps MFA (A):	15
Dimensions (HxWxD):	11-13/16x39-3/8x27-9/16
Panel (HxWxD):	N/AxN/AxN/A
Net Weight (lbs):	80
Weight with Panel (lbs):	N/A

Condensing Unit Details

Power Supply (V/Hz/Ph):	208-230/60/1ph
Power Supply Connections:	L1, L2, Ground
Min. Circuit Amps MCA (A):	16.5
Max. Overcurrent Amps MFA (A):	20
Max. Starting Current MSC(A):	
Rated Load Amps RLA (A):	7.1
Dimensions (HxWxD):	30-5/16x35-7/16x12-5/8
Net Weight (lbs):	150

Airflow Rate (CFM wet coil)635/582/529Moisture Removal (pt/h):635/582/529Gas Pipe Connection (inch):1/2Liquid Pipe Connection (inch):1/4Condensate Connection (inch):1Sound Pressure Level (dBA):37Static Pressure Rated/Max (inWg)0.4 / 0.8/0.8

Compressor Type:	Inverter
Capacity Control Range (%):	35 - 100
Airflow Rate (CFM):	1835
Gas Pipe Connection (inch):	5/8
Liquid Pipe Connection (inch):	3/8
Sound Pressure Level (dBA):	49
Sound Power Level (dBA):	

System Details

R-410A
5.1
0.036lbs/ft
-
164 ft

Max. Pipe Length (Vertical ft):	98 ft
Cooling Operation Range (°F):	23 - 115
Cooling Range w/Baffle (°F):	0 - 115
Heating Operation Range (°F):	N/A
Heating Range w/Baffle (°F):	N/A




Project Name:	
Location:	Approval:
Engineer:	Date:
Submitted to:	Construction:
Submitted by:	Unit #:
Reference:	Drawing #:

Approval:	
Date:	
Construction:	
Unit #:	
Drawing #:	
	_

Dimensional Drawing - Indoor Unit

Daikin AC TRL Generated Submittal Data



Daikin AC (Americas), Inc., 1645 Wallace Drive - Suite 110, Carrollton, TX 75006


FBQ18PVJU



Project Name: Location: Approval: Engineer: Date: Submitted to: Construction: Submitted by: Unit #: Reference: Drawing #:

Dimensional Drawing - Condensing Unit

Daikin AC TRL Generated Submittal Data



RZR18PVJU

(Daikin's products are subject to continuous improvements. Daikin reserves the right to modify product design, specifications and information in this data sheet without notice and without incurring any obligations)



Project Name:	
Location:	Аррі
Engineer:	Date
Submitted to:	Con
Submitted by:	Unit
Reference:	Drav

Approval:	
Date:	
Construction:	
Unit #:	
Drawing #:	



FBQ18PVJU

Daikin AC TRL Generated Submittal Data

Std U.S. Warranty: 7yrs Compressor, 5yrs Parts



RZR18PVJU

Std U.S. Warranty: 7yrs Compressor, 5yrs Parts

Daikin AC (Americas), Inc., 1645 Wallace Drive - Suite 110, Carrollton, TX 75006

Page 4 of 4 www.daikinac.com