

Submittal Data: System 30RLX ASU30RLX & AOU30RLX



Job Name: _____ Location: _____

Purchaser: _____

Engineer: _____

Submitted To: _____ For: Reference Approval Construction

Submitted By: _____

Unit Designation: _____ Schedule No. _____ Model No.: _____

Capacities:

| | |
|--------------------------------------------|--------------|
| Cooling | 30,600 BTU/h |
| Outdoor Design Temp. <i>F° DB/WB</i> | 95/75 |
| Heating | 32,000 BTU/h |
| Outdoor Design Temperature <i>F° DB/WB</i> | 47/43 |
| HSPF | 9.5 |
| SEER | 17.5 |
| EER <i>Cooling/Heating</i> | 10.0/10.7 |
| Voltage/Frequency/Phase | 208-230/60/1 |

Indoor Unit:

| | |
|------------------------------------------------|----------------|
| Noise Level Cooling <i>db (A) - H/ M/ L/ Q</i> | 49/ 42/ 37/ 33 |
| Noise Level Heating <i>db (A) - H/ M/ L/ Q</i> | 49/ 42/ 37/ 33 |
| Weight | 31 lbs. |

Outdoor Unit:

| | |
|------------------------------------|----------|
| Noise Level <i>Cooling/Heating</i> | 54/55 |
| Recommended Fuse Size | 30A |
| Min. Ampacity | 13.1A |
| Running Current <i>Cooling</i> | 13.2A |
| Running Current <i>Heating</i> | 10.5A |
| Weight | 137 lbs. |

Refrigerant Piping:

| | |
|------------------------------|---------|
| Max Ht. Difference | 98 ft. |
| Max Total or Combined Length | 164 ft. |
| Discharge Vapor Line (O.D.) | 3/8 in. |
| Suction (O.D.) | 5/8 in. |

- ◆ Six year compressor warranty
- ◆ Two year parts warranty
- ◆ Digital wireless remote control
- ◆ 4-way automatic louvers
- ◆ Min Heat (50F heating set point)
- ◆ Built in Low Ambient
- ◆ Auto Restart/ Reset
- ◆ 24 hour timer
- ◆ Optional Wired Remote Control
- ◆ Dry mode
- ◆ Refrigerant R410A
- ◆ Quiet Mode

Notes:

OUTLINE AND DIMENSIONS

